

ICON SEPTTECH
COMMISSION CHECKLIST

**Owner to complete registration and forward to Icon Septech or Warranty is Null and Void
Turbojet 2000 Deluxe Sewage Treatment Plant (STP)**

Date Unit Purchased * _____ / _____ / _____ Invoice No. _____

**Warranty commences from date of purchase*

Owners Name:.....	Mobile no.....	Home No
SITE ADDRESS		
Lot No.....	House No.....	Street/ Rd
Suburb/ Town.....		Postcode
Council/ Shire		
POSTAL ADDRESS (if different from above)		
PO Box	House No	Street/Rd.....
Suburb/ Town.....		Postcode
Date Delivered:	Delivered By:.....	Ph:.....
Date Installed:	Installed By:	Ph:.....
Electricians Name:	Licence No:	Ph:
Control Panel No:.....	Circ Pump No:	Irrigation Pump No:

ALL PROCEDURES MUST BE COMPLETED BEFORE COMMISSIONING.

Note: A re-commissioning fee may be charged if all procedures are not compliant with Septech Specifications

NO WARRANTY UNTIL COMPLETED

TICK

1	Top manifold assembly no greater than 300mm below ground level mounted to top saddle	
2	Fill the Septic and turbojet tanks with water to avoid floatation, ready for commissioning	
3	Seal joins between tank, saddle and extensions to avoid water (rain) and tree roots entering	
4	Sludge return line run in conduit to Primary tank. Cut hose, only (100mm) 4 inch or 10mm goes into Septic tank to avoid syphoning.	
5	Power to be wired direct from switchboard, 1.20AMP separate circuit and not covered by RCD to the control panel. Mount control panel on outside wall of building 1.6m high (out of direct weather) to allow easy access for servicing.	
6	Power from control panel must be 3 core Versolex (or approved equivalent) with 1.0mt spare. Alarm Float 2 core Versolex with 1.0mt spare and heatshrink joined direct to inside of saddle (sealed in resin cored heatshrink) to circulation pump.	
7	Power from control panel direct to irrigation pump and to float alarm (sealed in resin cored heatshrink) in Chlorination pit (if required)	
8	All electrical wiring to run through conduit as per electrical regulations	
9	Seal around conduit and pipes to prevent ingress of ground water inside and outside of tanks	
10	Ensure there is continuous 240 volt electrical power to the Sewage Treatment Plant.	
11	Ensure all lids remain fully exposed above ground level.	
12	All pipe entries into tanks must be sealed inside and outside to avoid water, dirt and roots into system	
13	Make sure irrigation lines are connected to the disposal pump	

ALL WIRING IS SUBJECT TO FLOODING AND MUST BE WATERPROOF

IF NOT WIRED TO SEPTTECH SPECIFICATIONS, SYSTEM WILL NOT BE COMMISSIONED AND ALL WARRANTY IS NULL AND VOID